

FG-A-OD

Alarm Unit for Hydrocarbon Leak Detection

Product Datasheet





- Analog Leak Detection System
- Leak Detection of Hydrocarbons
- ► Three LED Indicators
- ► Two Output Relays

Description

The FG-A-OD alarm unit is designed to be used with FG-OD hydrocarbon range of hydrocarbon sense cables and probes, to provide rapid detection of non-conductive hydrocarbon liquids and solvent.

System Responses:

- Leak Detection: Triggers an audible alarm, activates the red LED, and activates the leak relay.
- Cable Break: Triggers an audible alarm, activates the yellow LED, and activates the cable break relay.

Alarm Control:

■ The "SOUND OFF" button on the front panel allows manual muting of the audible alarm. However, the LED and relay remain activated until the fault is resolved. Once corrected, the system automatically returns to normal status.

Key Advantages

- Zone Control: The FG-A-OD unit can control one length of sense cable up to 65 ft (20 m).
- Fault Detection: The system detects cable break faults to ensure reliable monitoring.
- Clear Alerts: Visual and audible indicators differentiate between leak and cable break faults.
- Easy Installation: Easily accessible terminals enable quick and hassle-free installation.
- Reliable & Simple: The FG-A-OD unit is accurate and user-friendly, making it ideal for small applications where precise leak location is not required.

Panel Description

- 1: The leak signal (red LED) indicates that the system has detected a liquid leak.
- 2: The continuity signal (yellow LED) indicates that the system has detected a circuit interruption.
- 3: The power supply signal (green LED) indicates that the system is in normal operation.
- 4: The button is used to stop the audible alarm.



Identification Codes

FG-A-OD F	Leak Detection Alarm Unit (Wall Mounted) 240VAC - Oil Detection
Accessories:	
FG-CLOD	Leader Cable 11.5 ft (3.5 m)
FG-TMOD	End Termination
FG-NOD 'N'	OD Bus 8771 Neutral Cable 'N' [9, 22, 49, 98 ft] [1, 3, 7, 15, 30 m] with Connectors
CF-0D50	50 Hold-down Clips with Adhesive
ES-OD	40 Signal Tags

Certifications



FG-OD sense cables which are certified by ATEX can be connected to the FG-A-OD alarm & location unit. All the connections in the FG-A alarm unit must be done with the power supply switched off. Read carefully the installation procedure for the FG-A-OD alarm unit.

This brochure has been carefully prepared to ensure technical accuracy but is only intended for promotional use. TTK cannot guarantee that the information contained herein contains no errors or omissions, and hence does not accept responsibility related to the use of its equipment. TTK maintain its obligations set forth in the Standard Terms and Conditions of Sale and will not, under any circumstances, assume liability for any incidental damages, indirect or consequential, arising from the sale, resale, use or misuse of this product. The purchaser(s) accept their responsibility as the sole judge(s) of the adaptability of the product for the intended use.

FG-NET, FG-SYS and TOPSurveillance are trademarks of TTK S.A.S. $\,$ © TTK 2025 $\,$

- TTK USA Inc. / 100 S. Broad Street, Suite 730 Philadelphia, PA 19110 / Tel. +1 610 304 2270 / www.ttkusa.com / sales@ttkusa.com
- TTK Headquarters / 19, rue du Général Foy /75008 Paris / France / T: +33.1.56.76.90.10 / F: +33.1.55.90.62.15 / www.ttk.fr / ventes@ttk.fr